


CERTIFICATE OF SEISMIC COMPLIANCE

For BreakMaster Load Interrupter Switch

Qualified to IEEE-693-2005

Qualified to IBC-2006

$S_{ds} = 2.0g$, $S_s = 300\%$, $I_p = 1.5$, for all z/h
in accordance with ICC-ES-AC156.



Lowest equipment natural frequency: 6.0 Hz Qualified by shake-table testing,
Clark Dynamic Test Laboratory, Oct. 2000

**THIS IS TO CERTIFY THAT THE ABOVE NAMED EQUIPMENT MEETS OR EXCEEDS
ALL OF THE ABOVE REQUIREMENTS ACCORDING TO IEEE-693-2005 AND IBC-2006.**

Certification Report Prepared by

W. E. Gundy & Associates, Inc.
P.O.Box 2900, Hailey, ID, 83333

See GE document 10095791P1 for Certification Report, interpretation of test data and P.E. stamp.

